

Annual CCR Fugitive Dust Control Report

A.B. Brown Generating Station

December 7, 2023

40 CFR §257.80(c) Annual Fugitive Dust Control Report

The owner or operator of a CCR unit must prepare an annual CCR fugitive dust control report that includes a description of the actions taken by the owner or operator to control CCR fugitive dust, a record of all citizen complaints, and a summary of any corrective measures taken.

The A.B. Brown Generating Station has not received any citizen complaints regarding CCR fugitive dust since the prior Annual CCR Fugitive Dust Control Report prepared on December 7, 2022.

Water trucks are being utilized to control dust. Soil Sement, a polymer emulsion product used to seal the ash pond was applied from November 2, 2023, to November 17, 2023.